

The County of Yuba

Community Development & Services Agency

Kevin Mallen, Director

Phone – (530) 749-5430 • Fax – (530) 749-5434
915 8th Street, Suite 123
Marysville, California 95901

www.co.yuba.ca.us



BUILDING
749-5440 • Fax 749-5616

CODE ENFORCEMENT
749-5455 • Fax 749-5464

ENVIRONMENTAL HEALTH • CUPA
749-5450 • Fax 749-5454

HOUSING & COMMUNITY SERVICES
749-5460 • Fax 749-5464

PLANNING
749-5470 • Fax 749-5434

PUBLIC WORKS • SURVEYOR
749-5420 • Fax 749-5424

FINANCE AND ADMINISTRATION
749-5430 • Fax 749-5434

5764 GRIFFITH AVENUE, LINDA
Contract #2013-N3P5764GRI

RFI No. 1

September 18, 2013

1. Question: What are Yuba County Environmental Health's requirements for demolition of the septic tank (Item #3)

Answer:

- Obtain septic tank destruction permit from Yuba County Environmental Health.
- Pump septic tank and properly dispose of contents by a company that is under permit to operate in Yuba County.
- Furnish Pumping Report to Yuba County Environmental Health.
- Destroy septic tank. This can be done several ways:
 1. Backfill tank:
 - a) Break a hole in the bottom of each section of the tank to provide for drainage.
 - b) Backfill the tank with earth, sand or gravel material to a depth of approximately one foot below finish grade.
 - c) The tank lid may be broken into small pieces and placed into the tank with gravel, be careful not to create any hollow voids.
 - d) The remaining fill to surface level may be of any approved material and should be graded to drain.
 2. Remove entire tank:
 - a) Remove entire tank and haul to a landfill site.
 - Applicant should contact the landfill ahead of time to see if disposal of tank is currently allowed.
 - b) Hole shall be filled and compacted with soil.
- Furnish progressive pictures of proper destruction to Yuba County Environmental Health.